

**VPLX.EX5322**
Valves, Alarm[Page Bottom](#)

Valves, Alarm[See General Information for Valves, Alarm](#)**PROTECTOR SAFETY IND CO**

EX5322

3 ALLEY 16 LANE 228 SEC 2 NANKAN RD
LU CHU HSIANG
TAOYUAN HSIEN, 338 TAIWAN

Model P, 4 and 6 in. size with flanged ends for horizontal or vertical installation used with Model F retard chamber and Model F-1 water motor gong.

Model H, 3, 4, 6 and 8 in. size for rated pressure not exceeding 250 psi for vertical installation only may be provided with constant pressure trim or variable pressure trim for use with Model RC9 retard chamber and Model GA water motor and gong with the end connections: flanged-flanged, flanged-grooved and grooved-grooved.

[Last Updated](#) on 2014-04-14

[Questions?](#)[Print this page](#)[Terms of Use](#)[Page Top](#)

© 2014 UL LLC

When the UL Leaf Mark is on the product, or when the word "Environment" is included in the UL Mark, please search the [UL Environment database](#) for additional information regarding this product's certification.

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL's Follow-Up Service. Only those products bearing the UL Mark should be considered to be Certified and covered under UL's Follow-Up Service. Always look for the Mark on the product.

UL permits the reproduction of the material contained in the Online Certification Directory subject to the following conditions: 1. The Guide Information, Assemblies, Constructions, Designs, Systems, and/or Certifications (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from the Online Certifications Directory with permission from UL" must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "© 2014 UL LLC".